

Notified Body pursuant to the Construction Products Regulation  
Permission № CPR-26-NB2765/03.05.2018 of  
Ministry of Regional Development and Public Works

## Certificate of Constancy of Performance

№ 2765-CPR-0165/3

In compliance with Regulation (EU) № 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

### Heat detector Short-circuit isolator (Trade name of the product: NOVA-AHD)

(the characteristics and the performances are described in Annex I which is an inseparable part of this certificate)

placed on the market under the name of

**ELEKS Elektrik Elektronik Sistemler San. Ve Tic. A.Ş.**  
Şerifali Mah. Bayraktar Bulvarı. Emin Sok. No:3 34775 Yukarı Dudullu/Ümraniye,  
İstanbul, Turkey

and produced in the manufacturing plant

Şerifali Mah. Bayraktar Bulvarı. Emin Sok. No:3 34775 Yukarı Dudullu/Ümraniye,  
İstanbul, Turkey

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

**EN 54-17:2005**  
**EN 54-17:2005/AC:2007**  
**EN 54-5:2000**  
**EN 54-5:2000/A1:2002**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the  
**constancy of performance of the construction product**

This certificate was first issued on 19.03.2020 and will remain valid until 21.03.2027 or neither the harmonised standard, the construction product, the assessment and verification of constancy of performance methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

21.03.2024

Manager of SZUTEST Ltd

Asen Hristov



The validity of certificate can be traced on <http://public.szutest.com.tr/Certificate/Index>



Notified Body pursuant to the Construction Products Regulation  
Permission № CPR-26-NB2765/03.05.2018 of  
Ministry of Regional Development and Public Works

# Certificate of Constancy of Performance

№ 2765-CPR-0165/3

## Annex I

**Product:** Heat detector, Short-circuit isolator

**Intended use:** fire safety

**Trade name of the product:** NOVA-AHD Addressable Heat Detector with Isolator

### Performance Characteristics:

Essential Characteristics	Performance	Harmonized standards
Nominal activation conditions/Sensitivity, Response delay (response time) and Performance under fire conditions	Pass	EN 54-5:2000 EN 54-5:2000/A1:2002
Tolerance to supply voltage	Pass	EN 54-5:2000 EN 54-5:2000/A1:2002
Operational reliability	Pass	EN 54-5:2000 EN 54-5:2000/A1:2002
	NPD	EN 54-17:2005 EN 54-17:2005/AC:2007
Performance parameters under fire conditions	Pass	EN 54-17:2005 EN 54-17:2005/AC:2007
Durability of operational reliability, temperature resistance	Pass	EN 54-17:2005 EN 54-17:2005/AC:2007 EN 54-5:2000 EN 54-5:2000/A1:2002
Durability of operational reliability, humidity resistance	Pass	
Durability of operational reliability, corrosion resistance	Pass	
Durability of operational reliability, vibration resistance	Pass	
Durability of operational reliability, electrical stability	Pass	

**Placed on the market under the name of:** ELEKS Elektrik Elektronik Sistemler San. Ve Tic. A.Ş.

**Produced in the manufacturing plant:** Şerifali Mah. Bayraktar Bulvarı. Emin Sok. No:3 34775 Yukarı Dudullu/Ümraniye, İstanbul, Turkey

21.03.2024

Manager of SZUTEST Ltd

Asen Hristov

The validity of certificate can be traced on <http://public.szutest.com.tr/Certificate/Idex>

The certificate will be validated each year after an annual surveillance audit.

Page 1 / 1