

Notified Body pursuant to the Construction Products Regulation  
Permission № CPR-26-NB2765/03.05.2018 of  
Ministry of Regional Development and Public Works

## Certificate of Constancy of Performance № 2765-CPR-0094

In compliance with Regulation (EU) № 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

### Fire detection and fire alarm systems – Power supply equipment, control and indicating equipment (Trade name of the product: EFIRE-ECP, NOVA-AFCP-B and AFCP-M)

(the characteristics and the performances are described in Annex I which is an inseparable part of this certificate)

placed on the market under the name of

**ELEKS Elektrik Elektronik Sistemler San. Ve Tic. A.Ş.**  
Şerifali Mah. Bayraktar Bulvarı. Emin Sok. No:3 34775 Yukarı Dudullu/Ümraniye,  
İstanbul, Turkey

and produced in the manufacturing plant

Şerifali Mah. Bayraktar Bulvarı. Emin Sok. No:3 34775 Yukarı Dudullu/Ümraniye,  
İstanbul, Turkey

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

**EN 54-4:1997, EN 54-4:1997/AC:1999, EN 54-4:1997/A1:2002,  
EN 54-4:1997/A2:2006;  
EN 54-2:1997, EN 54-2:1997/AC:1999, EN 54-2:1997/A1:2006**


under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product

This certificate was first issued on 25.01.2019 and will remain valid until 25.01.2027 or neither the harmonised standard, the construction product, the assessment and verification of constancy of performance methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

25.01.2024

Manager of SZUTEST Ltd

Asen Hristov



The validity of certificate can be traced on <http://public.szutest.com.tr/Certificate/Index>

The certificate will be validated each year after an annual surveillance audit

Notified Body pursuant to the Construction Products Regulation  
Permission № CPR-26-NB2765/03.05.2018 of  
Ministry of Regional Development and Public Works

## Certificate of Constancy of Performance № 2765-CPR-0094

### Annex I

**Product:** Power supply equipment, control and indicating equipment

**Intended use:** fire safety

**Trade name of the product:** EFIRE-ECP, NOVA-AFCP-B and AFCP-M

#### Performance Characteristics:

| Essential Characteristics                                     | Performance | Harmonized standards  |
|---|-------------|---|
| Performance under fire conditions                             | Pass        | EN 54-4:1997<br>EN 54-4:1997/AC:1999<br>EN 54-4:1997/A1:2002<br>EN 54-4:1997/A2:2006;<br>EN 54-2:1997<br>EN 54-2:1997/AC:1999<br>EN 54-2:1997/A1:2006 |
| Response delay (response time to fire)                        | Pass        |   |
| Operational reliability                                       | Pass        |   |
| Durability of operational reliability, temperature resistance | Pass        |   |
| Durability of operational reliability, vibration resistance   | Pass        |   |
| Durability of operational reliability, electrical stability   | Pass        |   |
| Durability of operational reliability, humidity resistance    | Pass        |   |
| Performance of power supply                                   | Pass        |   |

**Placed on the market under the name of:** ELEKS Elektrik Elektronik Sistemler San. Ve Tic. A.Ş.

**Produced in the manufacturing plant:** Şerifali Mah. Bayraktar Bulvarı. Emin Sok. No:3 34775 Yukarı Dudullu/Ümraniye, İstanbul, Turkey

25.01.2024

Manager of SZUTEST Ltd

Asen Hristov

The validity of certificate can be traced on <http://public.szutest.com.tr/Certificate/Index>

The certificate will be validated each year after an annual surveillance audit.

Page 1 / 1